



**Drinking Water Quality and Compliance
SaskWater Cupar Water Supply System
2017 Notification to Consumers**

The Water Security Agency (WSA) requires that, at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Permit to Operate a waterworks. The following is a summary of the SaskWater Cupar Water Supply System water quality and sample submission compliance record for the January 1, 2017 to December 31, 2017 time period. This report was completed on April 6, 2018. Readers should refer to the WSA's Municipal Drinking Water Quality Monitoring Guidelines, October 2012, EPB 202 for more information on minimum sample submission requirements and types of samples. Permit requirements for a specific waterworks may require more sampling than outlined in the Agency's monitoring guidelines. If consumers need to know more about drinking water in Saskatchewan, more detailed information is available from: <http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index-eng.php>.

BACTERIOLOGICAL QUALITY

Parameter	Limit	Regular Samples Required	Regular Samples Submitted	# Positive of Regular Submitted
Total Coliform	0 Organisms/100 mL	52	51	0
E. Coli	0 Organisms/100 mL	52	51	0
Background Bacteria	Less than 200/100 mL	52	51	0

Analysis is performed on a single sample for all parameters mentioned above. All waterworks are required to submit samples for bacteriological water quality; the frequency of monitoring depends on the population served by the waterworks.

WATER DISINFECTION

Chlorine Residual in Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit (either/or)	Range (mg/L)	# Tests Required	# Tests Submitted	# Adequate Chlorine
Free Chlorine	0.1 mg/L	0.77 – 1.12	52	51	51
Total Chlorine	0.5 mg/L	0.86 – 1.31	52	51	

A minimum of 0.1 milligrams per litre (mg/L) free chlorine residual **OR** 0.5 mg/L total chlorine residual is required at all times throughout the distribution system. An adequate chlorine is a result that indicates that the chlorine level is above the regulated minimums. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit.

Free Chlorine Residual for Water Entering Distribution System

Parameter	Limit (mg/L)	Range (mg/L)	# Tests Required	# Tests Performed	% Adequate Chlorine
Free Chlorine	At least 0.1	0.38 – 2.52	365	Continuous	100

Minimum 0.1 milligrams per litre (mg/L) free chlorine residual is required for water entering a distribution system. Residuals are continuously monitored and recorded. Tests normally performed on a daily basis by waterworks operators are recorded in operation records.

TURBIDITY

Turbidity in the Distribution System – From Test Results Submitted with Bacteriological Samples

Parameter	Limit (NTU)	Range (NTU)	# Tests Required	# Tests Performed	# Exceeding Limit
Turbidity	No standard	0.06 – 0.13	52	51	0

Turbidity for Water Entering the Distribution System

Parameter	Limit (NTU)	Range (NTU)	95 th Percentile (NTU)	# Tests Required	# Tests Performed	# of Months Exceeding 95 th Percentile Limit
Turbidity	< 1.0 – 95% of measurements made each month	0.02 – 1.00	0.05	365	Continuous	0

Turbidity is a measure of water treatment efficiency. Turbidity measures the “clarity” of the drinking water and is reported in Nephelometric Turbidity Units (NTU). All waterworks are required to monitor turbidity at the water treatment plant. The turbidity is done daily with bench testing instrument, as well as continuously with an on-line analyzer.

CHEMICAL – GENERAL

The Cupar Water Supply System is required to submit water samples for the WSA’s General Chemical category once every second year. 2017 is not a required sample year. Additional sampling was done for informational purposes. The last sample for General Chemical analysis was submitted on October 11, 2017. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	MAC	AO *	Sample Results	# of Samples Required	# of Samples Submitted
Total Alkalinity (mg/L)		500	83.5	0	1
Bicarbonate (mg/L)	No Objective		102	0	1
Calcium (mg/L)	No Objective		11	0	1
Carbonate (mg/L)	No Objective		0	0	1
Chloride (mg/L)		250	13.0	0	1
Fluoride (mg/L)	1.5		<0.05	0	1
Total Hardness (mg/L)		800	48	0	1
Hydroxide (mg/L)	No Objective		0	0	1
Magnesium (mg/L)		200	5	0	1
Nitrate (mg/L)	45		<0.2	0	1
pH (pH units)		6.5 - 9.0	8.2	0	1
Potassium (mg/L)	No Objective		<1	0	1
Sodium (mg/L)		300	50	0	1
Specific Conductivity (µs/cm)	No Objective		339	0	1
Sulphate (mg/L)		500	56.4	0	1
Total Dissolved Solids (mg/L)		1500	239	0	1

MAC – Maximum Acceptable Concentration

AO – Aesthetic Objective

*Objectives apply to certain characteristics of, or substances found, in water for human consumptive or hygienic use. Compliance with drinking water aesthetic objectives (AO) is not mandatory as these objectives are in the range where they do not constitute a health hazards. The AO for several parameters (including hardness, magnesium, sodium and total dissolved solids) consider regional differences in sources and quality.

CHEMICAL – HEALTH

The Cupar Water Supply System is required to submit water samples for the WSA’s Chemical Health category once every second year. 2017 is not a required sample year. Additional sampling was done for informational purposes. The last sample for Chemical Health analysis was submitted on October 11, 2017. Sample results indicated that the provincial drinking water quality standards were not exceeded.

Parameter	MAC (mg/L)	IMAC (mg/L)	AO (mg/L)	Sample Results (mg/L)	# of Samples Required	# of Samples Submitted
Aluminum	No Objective			<0.007	0	1
Antimony	0.006			<0.00016	0	1
Arsenic	0.010			0.00010	0	1
Barium	1.0			0.0011	0	1
Boron		5.0		0.3	0	1
Cadmium	0.005			<0.00015	0	1
Chromium	0.050			<0.00019	0	1
Copper			1.0	0.0164	0	1
Iron			0.3	<0.1	0	1
Lead	0.010			0.00020	0	1
Manganese			0.05	<0.01	0	1
Selenium	0.010			<0.00113	0	1
Silver	No Objective			<0.00020	0	1
Uranium	0.020			<0.00011	0	1
Zinc			5	<0.00400	0	1

MAC – Maximum Acceptable Concentrations

AO – Aesthetic Objective

IMAC – Interim Maximum Acceptable Concentrations

More information on water quality and sample submission performance may be obtained from:

SaskWater
 200-111 Fairford Street East
 Moose Jaw SK S6H 1C8
 Toll Free: 1-888-230-1111
 Fax: 306-694-3207
 Email: customerservice@saskwater.com